

**SECTION 00 9123
REBID ADDENDUM NUMBER 3**

DATE: December 6, 2016

TO: PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated **November 1, 2016**, with amendments and additions noted below. Where addendum items below modify a portion of the Bid Documents, the remainder of the Bid Document remains unchanged.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

This addendum consists of 1 page(s), in addition to the following document(s):

- A. RFI Log dated 12/6/2016.

CHANGES TO THE PROJECT MANUAL

Section 01 1200 MULTIPLE CONTRACT SUMMARY

- A. **ADD** Section 1.10 Item #66 on page 11 as follows: "66. Any and all doors and door hardware are to be salvaged and turned over to the owner. This includes but is not limited to locksets, cylinders, cores, door closers, hinges, kick plates, panic devices, etc."

Section 06 2000 FINISH CARPENTRY

- A. Change paragraph 2.17 A 3 to read as follows:
 - a. Provide four (4) additional black 4" high (nominal) toe kick grilles of the following lengths:
 - i. (1) 34 inches. Located in Room 321
 - ii. (2) 35 inches. Located in Room 321
 - iii. (1) 54 inches. Located in Room 312
 - b. Install over pre-existing openings in cabinet toe kicks.

Section 08 7100 DOOR HARDWARE

- A. Omit paragraph 3.3 A in its entirety.

CHANGES TO THE DRAWINGS

Classroom Elevations (Basement, first, second, and third floors)

- A. Provide ¾" CD plywood backer panel to the existing nominal ¼" thick recessed panel for each installation of clock box for timeclock on existing recessed panel. (Example of clock installation is shown on drawing A311, Room 202, elevation A).

END OF REBID ADDENDUM NUMBER 3

RSMP Phase 2A REBID
James Monroe High School
RFI LOG
12/6/16

Project Owner: Rochester City School District		CJS Architects		Project No 1522	
Constr. Manager: Campus CMG					
RFI #	Date Received	RFI SUBJECT	RFI RESPONSE		
210	12/02/16	In the door hardware specification section 087100, there is a section that addresses hardware pre-installation. On page 19, section 3.3 A.1 the architect has requested some hardware to be installed in the "shop." What is the intent behind this? Will this be considered during the bid process?	See Addendum No 3.		