

Date of Addendum: May 31, 2016

Original Date of Contract Documents: May 20, 2016

Owner

Rochester Joint Schools Construction Board
1776 North Clinton Avenue
Rochester, NY 14621

Architects and Engineers

Cannon Design
2170 Whitehaven Road
Grand Island, New York 14072

This Addendum amends Drawings and/or Specifications and/or Addenda for the above titled project, as indicated below, and is hereby incorporated into the Contract Documents as part thereof.

Bidders are required to acknowledge receipt of this Addendum in the space provided on the Proposal/Bid Form.

SPECIFICATIONS (PROJECT MANUAL)

1. SECTION 329200 – ATHLETIC FIELD CONSTRUCTION

A. Page 6, Paragraph 3.2, D., REVISE to read as follows:

“D. Respread screened topsoil to a minimum six to eight inch depth as required to meet...”

2. SECTION 329223 - SODDING

A. Page 5, Paragraph 3.2, D., REVISE to read as follows:

“D. Respread screened topsoil to a minimum six to eight inch depth as required to meet...”

DRAWINGS

1. DRAWING C-10

A. Sodding Notes, AMEND Note 3 to read as follows:

“4. For bidding purposes, the Contractor shall assume that 6 to 8 inches of topsoil exists within the footprint of the playfield area scheduled to be reconstructed. Once subgrade grading is complete, and after topsoil has been screened, the Contractor shall spread topsoil to a minimum depth of 6-8” over all areas of the site where earth has been exposed by excavating, cutting, filling or grading.”

2. DRAWING C-20

A. General Notes, AMEND Note 4 to read as follows:

“4. For bidding purposes, the Contractor shall assume that 6 to 8 inches of topsoil exists within the footprint of the playfield area scheduled to be reconstructed. Once subgrade grading is complete, and after topsoil has been screened, the Contractor shall spread topsoil to a minimum depth of 6-8” over all areas of the site where earth has been exposed by excavating, cutting, filling or grading.”

END OF ADDENDUM NO. 2