



BID ADDENDUM No. 3

PROJECT ROCHESTER CITY SCHOOL DISTRICT
ROCHESTER SCHOOL MODERNIZATION PROGRAM
PHASE 2b - SCHOOL WITHOUT WALLS COMMENCEMENT ACADEMY

CPL PROJECT No.: 14105.00

SED PROJECT Nos.: 26-16-00-01-0-045-021

DATE: May 26, 2017

Include this addendum as part of the Contract Documents. It supplements portions of the original specifications and drawing, the extent of which shall remain, except as revised herein:

REQUESTS FOR INFORMATION:

- 1.01 QUESTION:** Should there be C12 channel sill @ gym high window openings?
CPL RESPONSE: No, see revised sheet S202

CHANGES TO THE SPECIFICATIONS:

- 1.02 SPECIFICATION SECTION - 116623 - GYMNASIUM EQUIPMENT**
A. REVISE 116623.2.3.A to read as follows:
"A. Provide on the Side Court: #90220 Series Wall-Mounted Side-Fold backstop"

CHANGES TO THE DRAWINGS:

- 1.03 S202 - GYM FRAMING AND ELEVATIONS**
A. REPLACE drawing in its entirety with drawing attached
- 1.04 S401 - JOIST ELEVATIONS - SHEAR WALL PLAN**
A. REPLACE drawing in its entirety with drawing attached
- 1.05 A201B - GROUND FLOOR NEW WORK PLAN - AREA B**
A. REVISE door 101A-2 swing to swing into room 101A.
- 1.06 A401 - WALL SECTIONS**
A. REVISE in section 3/A401 B.O. ACCENT METAL PANEL datum to read 6'-8" to match dimension on exterior elevation 3/A300
B. REVISE in section 3/A401 B.O. ACCENT PANEL INSET datum to read 12'-8" to match dimension on exterior elevation 3/A300
- 1.07 A705 - ENLARGED GYM FLOOR PLAN AND ELEVATIONS**
A. REPLACE drawing in its entirety with drawing attached
- 1.08 P201A - GROUND FLOOR SANITARY, VENT & STORM PLUMBING WORK PLAN**
A. REVISE Alternate 5 note (at room 109) to read "Alternate 4"
B. REVISE Alternate 4 note (at student toilet rooms) to read "Alternate 5"
- 1.09 P202 - ROOF LEVEL GAS, ROOF DRAINS AND VENT PLUMBING WORK**

- A. REPLACE** drawing in its entirety with drawing attached
- 1.10 P301A - GROUND FLOOR DOMESTIC WATER PLUMBING WORK PLAN**
 - A. REVISE** Alternate 5 note (at room 109) to read "Alternate 4"
 - B. REVISE** Alternate 4 note (at student toilet rooms) to read "Alternate 5"
- 1.11 P501 - GROUND FLOOR FIRE PROTECTION PLAN**
 - A. REVISE** Alternate 5 note (at room 109) to read "Alternate 4"
 - B. REVISE** Alternate 4 note (at student toilet rooms) to read "Alternate 5"

END OF ADDENDUM No. 3