



PRE-BID ADDENDUM NO. 5 – Phase 2D

PROJECT: Edison Career & Technology High School
Phase 2D Renovations
655 Colfax Street
Rochester, NY 14606

S.E.D. PROJECT NUMBER: 26-16-00-01-0-111-032

DATE: July 22, 2019

FROM: LaBella Associates, DPC
300 State Street
Rochester, New York 14614

Include this Addendum as part of the Contract Documents. It supplements portions of the original specifications/project manual and drawings, the extent of which shall remain, except as revised herein:

BY:

Michael Ferreri, Project Manager
LaBella Associates, P.C
300 State Street, Suite 201
Rochester, NY 14614
(585) 454-6110
E-Mail: mferreri@labellapc.com



RFI RESPONSES

1) Pre-Bid RFI Question #36

a) Please confirm the pipe sizes coming in to the hydrodynamic separator.

i) RESPONSE:

Per the Utility Plan C301, the pipe coming into the HDS unit from the east is a 36" pipe. Revise detail 5 on sheet C-605 notes a 36" pipe (by others) in lieu of the 48" pipe noted.

2) Pre-Bid RFI Question #37

a) Per Addendum 3, the existing smoke hatches above the pool and gym are being replaced with skylights. The following questions then are created from an electrical scope:

- *What is to be done with the existing circuit at the smoke hatches to be replaced?*
- *Are smoke detectors required at skylights?*

i) RESPONSE:

Smoke detectors are not required at skylights. Existing detectors and relays at new skylight locations are to be removed and turned over to the District. Pull wiring back to source.

CHANGES TO THE SPECIFICATIONS

None

CHANGES TO THE DRAWINGS

None

ATTACHMENTS

None

End of Addendum 5