

ADDENDUM NO. 5

Rochester City School District

Dr. Walter Cooper, School #10

SED Control#: 26-16-00-01-0-037-021

SED DWT Control #: 26-16-00-01-7-999-020

SEI Project No.: 17-3016

January 21<sup>th</sup>, 2019



---

### **GENERAL INSTRUCTIONS:**

- Include this Addendum as part of the Construction Documents. This Addendum supplements portions of the original Drawings and Specifications, the intent of which shall remain, except as revised herein.
  - Work described in this Addendum shall be in accordance with the Specifications for like items in remainder of project and complete with all labor and materials included.
- 

### **REVISIONS TO THE PROJECT MANUAL:**

#### **SECTION 082550 – FRP/ALUMINUM FLUSH DOORS AND ALUMINUM FRAMING**

Item 5-1      **ADD** Sub-paragraph 2.2.H as follows:

“H. Fire-Rated FRP doors and frames as scheduled shall be based on the following: Model SL-20FR with compatible TGP (Technical Glass Products) fire rated steel door frame.” (this is the only exception to article 1.7.B for doors and frames to be by the same manufacturer.)

SECTION 082560 – AMP/ALUMINUM DOORS AND ALUMINUM STOREFRONT

Item 5-2      **ADD** Sub-paragraph 2.2.G as follows:

“G. Fire-Rated AMP doors and frames as scheduled shall be based on the following: Model SL-19FR with compatible TGP (Technical Glass Products) fire rated steel door frame.” (this is the only exception to article 1.7.B for doors and frames to be by the same manufacturer.)

**REVISIONS TO THE DRAWINGS:**

DRAWING NO. A1232 – WINDOW DETAILS

Item 5-3      **ADD** the following general note to this sheet: “Window panning shown on these details shall be a custom sub-frame with integral trim – profile to match detail 3/A1232 for all windows scheduled to receive custom panning.”

DRAWING NO. H1600 – HVAC SCHEDULES (Air Cooled Condenser Schedule):

Item 5-4      **REVISE** Air Cooled Condenser Schedule remarks to indicate Chiller, CH-1 shall be provided with hot gas bypass.

End of Addendum No. 5